

BULETIN ANALIZA NR. *22.6.8.2012*

## APE DEVERSATE IN IER

Indicator	UM	Valori max.admise	Valori obtinute	Observatii
pH	-	6,5-8,5	<i>8,1</i>	
Materii in suspensie	mg/l	60	<i>20,2</i>	
CBO <sub>5</sub>	mg/l	25	<i>7,1</i>	
CCO-Cr	mg/l	125	<i>29</i>	
Reziduu fiz	mg/l	2000	<i>1530</i>	
Azot amoniacal	mg/l	3	<i>0,1</i>	
Fe total	mg/l	5	<i>0,1</i>	

Sef sectie ing. Dihel Adela  
*Adela*